



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

HollyDell School

33 Hollydell Drive
Sewell, NJ 08080

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U119116	Field Blank	05/12/2022 06:55	05/23/2022 14:10	5.91	15.5	SM3113B
U119117	Sink-Sec III-KS	05/12/2022 06:57	05/23/2022 14:16	<2.00	15.5	SM3113B
U119118	Sink- Sec I-KS	05/12/2022 06:51	05/23/2022 14:23	<2.00	15.5	SM3113B
U119119	Sink-Nurse's Ofc-NS	05/12/2022 06:58	05/23/2022 14:30	<2.00	15.5	SM3113B
U119120	Sink-Kitchen-KS	05/12/2022 06:54	05/23/2022 14:36	<2.00	15.5	SM3113B
U119121	Water Cooler-Kitchen-KS	05/12/2022 06:55	05/23/2022 14:43	<2.00	15.5	SM3113B
U119122	Sink-SecII-KS	05/12/2022 06:53	05/23/2022 14:50	<2.00	15.5	SM3113B

Mark J. Riether, Lab Director

05/24/2022

Date



South Jersey Water Test, LLC

4077 South Black Horse Pike
Williamstown, NJ 08094
Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
NJ DEP Certification #08006

CHAIN OF CUSTODY RECORD

Customer:	Hollydell School
Contact:	Alan Gregory
Address:	303 Hollydell Drive Sewell, NJ 08080
Phone:	
Office:	
Fax:	

Lab ID#	Sample Location	Collection Date	Time	pH	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
1119116	Field Blank	5/12/22	0655	X		D	1 x 250	HNO3*	First Draw Lead	
1119117	Sink - Sec III - KS		6:57	X		D	1 x 250	HNO3*	First Draw Lead	
1119118	Sink - Sec I - KS		6:51	X		D	1 x 250	HNO3*	First Draw Lead	
1119119	Sink - Nurse's ofc - NS		6:58	X		D	1 x 250	HNO3*	First Draw Lead	
1119120	Sink - Kitchen - KS		6:54	X		D	1 x 250	HNO3*	First Draw Lead	
1119121	Water Cooler - Kitchen - KS		6:55	X		D	1 x 250	HNO3*	First Draw Lead	
1119122	Sink - Sec II - KS		6:53	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D:DRINKING WATER A:AQUEOUS S:SOIL SL:SLUDGE GW:GROUND WATER SW:SURFACE WATER WW:WASTE WATER

Turnaround Time	Standard	Report Format	Cooler Temp
	Standard	Report Format	
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____		NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Properly Preserved Yes <input type="checkbox"/> No <input type="checkbox"/>

Sampled by: <u>Myle Quilich</u> (Print)	Received by: <u>[Signature]</u> (Signature)	Date: <u>5/12/22</u>	Date: <u>5/12/22</u>	Time: <u>0740</u>	Time: <u>0740</u>
Relinquished by: <u>[Signature]</u> (Signature)	Received by: <u>[Signature]</u> (Signature)	Date: <u>5/12/22</u>	Date: <u>5/12/22</u>	Time: <u>0740</u>	Time: <u>0740</u>
Relinquished by: <u>[Signature]</u> (Signature)	Received by: <u>[Signature]</u> (Signature)	Date: _____	Date: _____	Time: _____	Time: _____